

**Coldwater Board of Public | Yearly Reliability report    Jan-Dec    2010    |    Jan-Dec    2009**

**Number of Outages per year(by Cause)**

0 Supply to City	0	0
1 Overhead Equipment Failure	10	4
2 Underground Equipment Failure	1	2
3 Weather	17	6
4 Birds, Animals, Snakes, etc.	5	15
5 Trees	6	2
6 Foreign Interference	0	0
7 Human	0	0
8 Other	0	0
9 Unknown	1	1
10 Vehicle	1	3
<b>Total</b>	<b>41</b>	<b>33</b>

**Outage Statistics**

ASAI (%)	99.988982	99.99667106
CAIDI (Long) (min)	46.829453	29.3847859
SAIDI (Long) (min)	57.907643	17.50069256
SAIFI (Long) (ints/tot cust)	1.2935879	0.647968237
SAIFI (Short) (ints/tot cust)	0	0